

FOGIENE SCIENCES PRIVATE LIMITED

17, 3rd floor, Patel Ram Reddy road,
Krishna Reddy layout, Domlur
Bangalore – 560071
Phone: 080-43740929
Email: support@fogiene.com



To,
M/S Jaitra Devices and Systems LLP
Block No 2, Sy no 84, 185 Phase 5,
IDA Cherlapally, Malikajiri Medchal,
Hyderabad - 500051

ANALYTICAL REPORT

Report number	FL-REP-20201464
Date of sample receipt	05-Jul-2021
Sampling by	Sampled by Fogiene Sciences
Sample code	FL-0855
Sample name	Bipolar Ioniser
Brand Name	'PRAAN'
Sample packing	Petri Plates
Analysed between	05-Jul-2021 to 14-Jul-2021
Date of report	14-Jul-2021

SL NO	Test Parameter	Pre	60 Minutes	Unit	Method	ASHARE Limits
1	Particulate Matter 2.5	37	15	µg/m ³	Instrument Method	150
2	Particulate Matter 10	45.5	22	µg/m ³	Instrument Method	35
3	Carbon dioxide (CO ₂)	936	616	ppm	Instrument Method	<1000
4	Carbon monoxide (CO)	0	0	ppm	Instrument Method	<1.7
5	Total Volatile Organic Compounds (TVOC)	0.71	0.15	mg/m ³	Instrument Method	Not specified
6	HCHO (Formaldehyde)	0.18	0.5	mg/m ³	Instrument Method	0.12
7	Relative Humidity	54	30	%	Instrument Method	Not specified
8	Temperature	33.33	34	°C	Instrument Method	Not specified

OPINION

The ioniser was tested in 240sqft area and was found to be performing good.

For Fogiene Sciences,

Authorised signatory

End of Report

Disclaimer: The test results in this report are only related to the sample received and analysed. This report shall not be reproduced in part or full without prior written approval from Fogiene Sciences Private Limited. The sample will be stored at the facility for a maximum of 30 days or till the shelf life expiry, whichever is earlier.

FL-REP-20201050